

WATER QUALITY
ASSOCIATION



GOLD SEAL CERTIFICATE

This is to certify that the drinking water system component herein has been independently tested and certified by the Water Quality Association in accordance with "Drinking Water System Components - Health Effects," NSF/ANSI-61. The material safety of the component listed has earned the Gold Seal.

Manufacturer:	Purolite Company (The)
Address:	150 Monument Road Bala Cynwyd, PA 19004
Model:	ArsenXnp
Product Type:	Ion Exchange Resin
Size:	14 - 52
Water Contact Temp:	CLD 23
Water Contact Material:	SYN
Listing Notes:	Ion Exchange Resin: The Certification of this media is only for applications with minimum flow greater than or equal to 1.87 gpm per cubic foot of resin. Certified for water treatment plant applications. This product has not been evaluated for point of use applications.
Issue Date:	Thursday, February 17, 2005
Expiration Date:	Sunday, March 22, 2009
Test Unit Number:	04126.001
Certificate Number:	CRT.101504.04126001.R3


Joseph F. Harrison, P.E., CWS-VI

17 February 2005
Effective Date